

**THIS DOCUMENT MUST BE POSTED AT THE HOT WORK SITE**

Project Name:	Location of Work	<b>FIRE SAFETY PRECAUTIONS</b>
CapU Project Manager:	Office/Cell:	
CapU Liaison	Office/Cell:	
Contractor:	Office/Cell:	
Site Supervisor:	Cell:	
Hot Worker:	Cell:	
Fire Watch:	Cell:	
<b>THE LOCATION WHERE THIS WORK WILL TAKE PLACE WILL BE EXAMINED BEFORE THE START OF THE HOT WORK AND ALL APPROPRIATE PRECAUTIONS WILL BE TAKEN.</b>		
<b>INSPECTIONS</b>		<p><b>BEFORE THE WORK</b> – All of the following precautions must be taken:</p> <ul style="list-style-type: none"> <li><input type="checkbox"/> Request FLSS shutdown for specific area</li> <li><input type="checkbox"/> Cutting/brazing/soldering and/or welding equipment must be thoroughly inspected and found to be in good repair, free of damage or defects.</li> <li><input type="checkbox"/> A multi-purpose dry chemical, portable fire extinguisher must be located such that it is immediately available to the work and is fully charged and ready to use</li> <li><input type="checkbox"/> At least one fire alarm pull station or means of contacting the fire department must be available and accessible to persons(s) conducting the hot work</li> <li><input type="checkbox"/> Floor areas under and least 10 m around the hot work must be swept clean of combustible and flammable materials</li> <li><input type="checkbox"/> All construction equipment fueling activities and fuel storage must be relocated at least 10 m away from the hot work</li> </ul> <p><b>WHERE APPLICABLE</b> – the following precautions will also be taken before the work begins:</p> <ul style="list-style-type: none"> <li><input type="checkbox"/> Fire resistant shields (fire retardant plywood, flameproof tarpaulin, metal, etc) must cover combustible floors</li> <li><input type="checkbox"/> Spark/slag catchers (fire retardant plywood, flameproof tarpaulin, metal, etc) must be suspended below any elevated cutting/welding operation</li> <li><input type="checkbox"/> All floor and wall openings must be covered to prevent sparks/slag from traveling to unprotected areas</li> <li><input type="checkbox"/> Containers in or on which cutting/welding will take place must be purged of flammable vapors</li> </ul> <p><b>DURING/AFTER THE WORK</b> –The following precautions will be taken:</p> <ul style="list-style-type: none"> <li><input type="checkbox"/> CapU’s Emergency Procedures must be posted along with this permit at the site</li> <li><input type="checkbox"/> Person(s) must be assigned to a fire watch during and for at least one hour after all hot work ceases</li> <li><input type="checkbox"/> Fire watch person(s) are to be supplied with a portable multipurpose dry chemical fire extinguisher and trained in its use</li> <li><input type="checkbox"/> A fire alarm pull station or means of contacting the fire department must be available and accessible to fire watch person(s)</li> <li><input type="checkbox"/> Intermittent walk-through of the area must be made for an additional three hours after the one hour fire watch period ends</li> </ul>
CapU Liaison Signature	Time:	
	Date:	
Fire Watch Signature <b>Before</b> Work	Time	
	Date:	
Fire Watch Signature <b>After</b> Work	Time:	
	Date:	
Fire Watch Signature 3 hours Post	Time:	
	Date:	
<b>RETURN FORM TO FACILITIES</b>		
Inspection by Project Manager Signature	Time:	
	Date:	
Fire & Life Safety Systems Restored Verified By:	Time:	
	Date:	